



防爆合格证

CONFORMITY CERTIFICATE OF EXPLOSION-PROOF

证号 CE15.2209X
Certificate No.

产品名称 Name of Product	音叉料位开关
型号及规格 Type of Product	Fork-11 I [1] [2] WA [3] [4]
防爆标志 Marking	Ex ia II C T6/T5/T4/T3/T2/T1 Ga
技术文件 Technical Documents	Q/JWVIBRATION04-2014
图号 Drawing No.	Fork-11.00
备注 Note (s)	本证书备注内容详见附件。

经对上述产品图样及技术文件的审查和样品的检验,其符合以下标准

By verifying the drawings and technical documents and checking samples, the product complies with the following standards

GB 3836.1-2010

GB 3836.4-2010

发给: 深圳计为自动化技术有限公司
Issued to:

本证失效日期: 2020-07-20

Date of Expire:

发证日期: 2015-07-20

Date of Issue:

中心印章
Center seal



中心主任
Director

刘红亮

石油和化学工业电气产品防爆质量监督检验中心
Supervision & Test Center of Ex-products of China Petroleum & Chemical Industry

注: 本证仅对与送检样品一致的产品有效

Note: This certificate is only valid for the products that are in accord with sample(s) tested and verified.

中心地址: 中国天津市丁字沽三号路 85 号

邮政编码: 300131

电话/传真: 022-26651066 / 26689116

Center Add: No.85 No.3 Road DingZiGu Tianjin China Post code: 300131

Tel/ Fax: 022-26651066/26689116

E-mail: pcec@pcec.com.cn

http://www.pcec.com.cn